

Annexure D

BUILDING SAFETY CERTIFICATE

No.

Dated: ...13/6/25... ..

It is certified that the existing building **JYOTI SENIOR SECONDARY SCHOOL, REWA** at **NH-7 Allahabad Road, in front of new bus stand, Rewa (M.P.)** is having block(s)/Floor(s) as per details below:

Detail of Block(s) in school	Block Admi	Block Senior	Block Labs	Block Primary	Block
No. of Floor(s) in the Block	03	03	04	04	

The building is owned/occupied by **Jyoti Senior Secondary School, Rewa** have complied with the building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of Er. S.K. Shrivastava on 12/6/2025 in the presence of **Fr. Jesbin Mathew, Manager, Jyoti Senior Secondary School, NH-7 Allahabad Road, In front of new bus stand, Rewa (M.P.)** and that the building/premises is fit for occupancy for running school with effect from 13/6/2025 for a period of one year years in accordance with rule and subject to compliance of the specific conditions as appended.

1. The buildings are well maintained, with proper position of staircases and exit.
2. The firefighting equipment are well connected to a tank of 2.0 Lakh liter water capacity.
3. Ramps are provided for children below 5 to 6 years for safety with separate staircase.
4. Surrounding open space is found proper.
5. The buildings are structurally sound & free from hazards like fire, flooding and encroachment etc.
6. The residual life of building is more than 30 years.

issued on 13/6/25 at Rewa by

* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

Signature with Seal:

Name: Er. S.K. Shrivastava

Designation: S.K. Consultant, Kbt Road Rewa

Address: Structural Engineer Nagar Nigam

Architect-M.P. Housing Board

0762240038 Mob.9827007225

Name and Address of Office/Department: Shrivastava

S.K. Consultant

Reg. "Structural Engineer"
Nagar Nigam Rewa.